

SAFE DRINKING WATER CERTIFICATE

No. UJL/XXX/01/2023

Date: 19/12/2023

It is certified that an inspection team headed by Asst. Engineer. D. C. Purohit
(Name of Officers with designation) from Uttarakhand Jal Sansthan, Karan Prayag
(Name of Department/Office) inspected the **SHRI GURU RAM RAI PUBLIC SCHOOL
KARANPRAYAG (CHAMOLI)** on 19 Dec. 2023 and found that the **SHRI
GURU RAM RAI PUBLIC SCHOOL KARANPRAYAG(CHAMOLI)** has safe drinking water
facilities for the students and members of staff of the institution as per the norms
prescribed by the Central/State/U.T.Govt.

The above is valid for a period of One Year.

Signature with Seal:

Name: Er. D.C. Purohit

Designation: Assistant Engineer

To,

THE PRINCIPAL

SHRI GURU RAM RAI PUBLIC SCHOOL KARANPRAYAG (CHAMOLI)

POST-LANGASU, DISTRICT-CHAMOLI, PIN-246446(UTTARAKHAND)

(Name & Address of the Institution)

Sachin Asthura
PRINCIPAL
SGRR PUBLIC SCHOOL
KARANPRAYAG



UTTARAKHAND JAL SANSTHAN KARANPRAYAG (CHAMOLI)

Water Quality Testing & Monitoring Laboratory Analysis Report

Name Of UJS Division	Uttarakhand Jal Sansthan, Karanprayag (Chamoli)
Name Of Block	Karanprayag
Name Of Scheme	Shri Guru Ram Rai Public School Karanprayag (Chamoli)
Type Of Source	Tank
Date of Sample Collection	18/12/2023
Date of Sample Receipt in Laboratory	18/12/2023
Date of commencing examination	19/12/2023
UJS Representative	Name - Er. D C Purohit Designation - A E

LAB TESTING DETAILS

S.N	Quality Parameter	Unit Of Measurement	BIS Desirable Limit	BIS Permissible Limit	Actual Level
1	PH	mg/l	6.5	8.5	7.55
2	Total Dissolved Solids	mg/l	500	2000	114
3	Turbidity	NTU	1	5	0.36
4	Residual Free Chlorine	mg/l	0.2	1	0.0
5	Chloride	mg/l	250	1000	2.5
6	Alkalinity as CaCo ₃	mg/l	200	600	72
7	Total Hardness	mg/l	200	600	78
8	Calcium	mg/l	75	200	16
9	Magnesium	mg/l	30	100	9.23
10	E-Coli	MPN/100 ml	0	0	-
11	Total Coliform	MPN/100 ml	0	0	-
12	Colour	Hazen	5	15	5
13	Odour	-	-	-	Agreeable
14	Taste	-	-	-	Agreeable

(D C Purohit)
A. E.

सहायक अभियन्ता
उत्तराखण्ड जल संस्थान
कानप्रायग (चमोली)

(Suraj Negi)
Chemist

SUB-DIVISIONAL LEVEL
WATER QUALITY TESTING
& MONITORING LABORATORY
CHAMOLI

PRINCIPAL
SGRR PUBLIC SCHOOL
KARANPRAYAG

HEALTH & SANITARY CONDITION CERTIFICATE

No. 05/NPP/KPG/MISS/2023-24

Date: 20.12.2023

It is certified that an inspection team headed by Sh.Nitin Sati, Health & Sanitary Inspector from Nagar Palika Parishad Karanprayag inspected the SHRI GURU RAM RAI PUBLIC SCHOOL KARANPRAYAG (CHAMOLI) on 19.12.2023 and found that the SHRI GURU RAM RAI PUBLIC SCHOOL KARANPRAYAG (CHAMOLI) is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T.Govt.

The above is valid for a period of **One Year**.

Signature with Seal:

Name : Nitin Sati

Designation : Health & Sanitary Inspector

Nitin Sati
20/12/2023
सफाई निरीक्षक
नगर पालिका परिषद
कर्णप्रयाग (चमोली)

To,

THE PRINCIPAL

SHRI GURU RAM RAI PUBLIC SCHOOL KARANPRAYAG (CHAMOLI)
POST-LANGASU, DISTRICT-CHAMOLI, PIN-246446(UTTARAKHAND)

Satish
PRINCIPAL
SGRR PUBLIC SCHOOL
KARANPRAYAG